

2012 International Energy Conservation Code: Chapter 4 [CE] Commercial Energy Efficiency

Section C402 Building Envelope Requirements



sghconcepts.com • 844.255.9393

C402.1 General (Prescriptive).

The building thermal envelope shall comply with Section C402.1.1. Section C402.1.2 shall be permitted as an alternative to the R-values specified in Section C402.1.1.

C402.1.1 Insulation and fenestration criteria. The building thermal envelope shall meet the requirements of Tables C402.2 and C402.3 based on the climate zone specified in Chapter 3. Commercial buildings or portions of commercial buildings enclosing Group R occupancies shall use the R-values from the "Group R" column of Table C402.2. Commercial buildings or portions of commercial buildings enclosing occupancies other than Group R shall use the R-values from the "All

other" column of Table C402.2. Buildings with a vertical fenestration area or skylight area that exceeds that allowed in Table C402.3 shall comply with the building envelope provisions of ANSI/ASHRAE/IESNA 90.1.

C402.1.2 U-factor alternative. An assembly with a U-factor, C-factor, or F-factor equal or less than that specified in Table C402.1.2 shall be permitted as an alternative to the R-value in Table C402.2. Commercial buildings or portions of commercial buildings enclosing Group R occupancies shall use the U-factor, C-factor, or F-factor from the "Group R" column of Table C402.1.2. Commercial buildings or portions of commercial buildings enclosing occupancies other than Group R shall use the U-factor, C-factor or F-factor from the "All other" column of Table C402.1.2.

Genwall (an ICBP) complies with the alternative method C402.1.2 - an assembly tested "U" factor value.

U-.064 = R-15.6.

Typical 3" panel is R-20.

TABLE C402.1.2

OPAQUE THERMAL ENVELOPE ASSEMBLY REQUIREMENTS

CLIMATE ZONE	1		2		3		4 EXCEPT MARINE		5 AND MARINE 4		6		7		8	
	All Other	Group R	All Other	Group R	All Other	Group R	All Other	Group R	All Other	Group R	All Other	Group R	All Other	Group R	All Other	Group R
ROOFS																
Insulation entirely above deck	U-0.048	U-0.048	U-0.048	U-0.048	U-0.048	U-0.048	U-0.039	U-0.039	U-0.039	U-0.039	U-0.032	U-0.032	U-0.028	U-0.028	U-0.028	U-0.028
Metal buildings	U-0.044	U-0.035	U-0.035	U-0.035	U-0.035	U-0.035	U-0.035	U-0.035	U-0.035	U-0.035	U-0.031	U-0.031	U-0.029	U-0.029	U-0.029	U-0.029
Attic and other	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.027	U-0.021	U-0.021	U-0.021	U-0.021	U-0.021	U-0.021	U-0.021
WALLS, ABOVE GRADE																
Mass	U-0.142	U-0.142	U-0.142	U-0.123	U-0.110	U-0.104	U-0.104	U-0.090	U-0.078	U-0.078	U-0.078	U-0.071	U-0.061	U-0.061	U-0.061	U-0.061
Metal building	U-0.079	U-0.079	U-0.079	U-0.079	U-0.079	U-0.052	U-0.052	U-0.052	U-0.052	U-0.052	U-0.052	U-0.052	U-0.052	U-0.039	U-0.052	U-0.039
Metal framed	U-0.077	U-0.077	U-0.077	U-0.064	U-0.064	U-0.064	U-0.064	U-0.064	U-0.064	U-0.064	U-0.064	U-0.057	U-0.064	U-0.052	U-0.045	U-0.045
Wood framed and other	U-0.064	U-0.064	U-0.064	U-0.064	U-0.064	U-0.064	U-0.064	U-0.064	U-0.064	U-0.064	U-0.051	U-0.051	U-0.051	U-0.051	U-0.036	U-0.036
WALLS, BELOW GRADE																
Below-grade wall ^b	C-1.140	C-1.140	C-1.140	C-1.140	C-1.140	C-1.140	C-0.119	C-0.119	C-0.119	C-0.119	C-0.119	C-0.119	C-0.092	C-0.092	C-0.092	C-0.092
Floors																
Mass	U-0.322	U-0.322	U-0.107	U-0.087	U-0.076	U-0.076	U-0.076	U-0.074	U-0.074	U-0.074	U-0.064	U-0.064	U-0.057	U-0.055	U-0.051	U-0.055
Joist/framing	U-0.066	U-0.066	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033	U-0.033
SLAB-ON-GRADE FLOORS																
Unheated slabs	F-0.73	F-0.73	F-0.73	F-0.73	F-0.73	F-0.73	F-0.54	F-0.54	F-0.54	F-0.54	F-0.54	F-0.54	F-0.52	F-0.40	F-0.40	F-0.40
Heated slabs	F-0.70	F-0.70	F-0.70	F-0.70	F-0.70	F-0.70	F-0.65	F-0.65	F-0.58	F-0.58	F-0.58	F-0.58	F-0.58	F-0.55	F-0.55	F-0.55

^a Use of opaque assembly U-factors, C-factors, and F-factors from ANSI/ASHRAE/IESNA 90.1 Appendix A shall be permitted, provided the construction complies with the applicable construction details from ANSI/ASHRAE/IESNA 90.1 Appendix A.

^b Where heated slabs are below grade, below-grade walls shall comply with the F-factor requirements for heated slabs.



C402.2 Specific insulation requirements (Prescriptive). Opaque assemblies shall comply with Table C402.2. Where two or more layers of continuous insulation board are used in a construction assembly, the continuous insulation boards shall be installed in accordance with Section C303.2. If the continuous insulation board manufacturer's installation instructions do not address installation of two or more layers, the edge joints between each layer of continuous insulation boards shall be staggered.

- For SI: 1 inch = 25.4 mm. ci = Continuous insulation. NR = No requirement.
 LS = Liner System—A continuous membrane installed below the purlins and uninterrupted by framing members. Uncompressed, unfaced insulation rests on top of the membrane between the purlins.
- ^a Assembly descriptions can be found in ANSI/ASHRAE/IESNA Appendix A.
 - ^b Where using R-value compliance method, a thermal spacer block shall be provided, otherwise use the U-factor compliance method in Table C402.1.2.
 - ^c R-5.7ci is allowed to be substituted with concrete block walls complying with ASTM C 90, ungrouted or partially grouted at 32 inches or less on center vertically and 48 inches or less on center horizontally, with ungrouted cores filled with materials having a maximum thermal conductivity of 0.44 Btu-in/h-*f* °F.
 - ^d Where heated slabs are below grade, below-grade walls shall comply with the exterior insulation requirements for heated slabs. e. Steel floor joist systems shall be insulated to R-38.

**TABLE C402.2
 OPAQUE THERMAL ENVELOPE REQUIREMENTS^a**

CLIMATE ZONE	1		2		3		4 EXCEPT MARINE		5 AND MARINE 4		6		7		8		
	All Other	Group R	All Other	Group R	All Other	Group R	All Other	Group R	All Other	Group R	All Other	Group R	All Other	Group R	All Other	Group R	
ROOFS																	
Insulation entirely above deck	R-20ci	R-20ci	R-20ci	R-20ci	R-20ci	R-20ci	R-25ci	R-25ci	R-25ci	R-25ci	R-30ci	R-30ci	R-35ci	R-35ci	R-35ci	R-35ci	
Metal buildings	R-19 +	R-19 +	R-19 +	R-19 +	R-19 +	R-19 +	R-19 +	R-19 +	R-19 +	R-19 +	R-25 +	R-25 +	R-30 +	R-30 +	R-30 +	R-30 +	
(with R-5 thermal blocks) ^{a, b}	R-11 LS	R-11 LS	R-11 LS	R-11 LS	R-11 LS	R-11 LS	R-11 LS	R-11 LS	R-11 LS	R-11 LS	R-11 LS	R-11 LS	R-11 LS	R-11 LS	R-11 LS	R-11 LS	
Attic and other	R-38	R-38	R-38	R-38	R-38	R-38	R-38	R-38	R-38	R-49	R-49	R-49	R-49	R-49	R-49	R-49	
WALLS, ABOVE GRADE																	
Mass	R-5.7ci	R-5.7ci	R-5.7ci	R-7.6ci	R-7.6ci	R-9.5ci	R-9.5ci	R-11.4ci	R-11.4ci	R-13.3ci	R-13.3ci	R-15.2ci	R-15.2ci	R-15.2ci	R-25ci	R-25ci	
Metal building	R-13 + R-6.5ci	R-13 + R-6.5ci	R-13 + R-6.5ci	R-13 + R-13ci	R-13 + R-6.5ci	R-13 + R-13ci	R-13 + R-13ci	R-13 + R-13ci	R-13 + R-13ci	R-13 + R-13ci	R-13 + R-13ci	R-13 + R-13ci	R-13 + R-13ci	R-13 + R-19.5ci	R-13 + R-13ci	R-13 + R-19.5ci	
Metal framed	R-13 + R-5ci	R-13 + R-5ci	R-13 + R-5ci	R-13 + R-7.5ci	R-13 + R-7.5ci	R-13 + R-7.5ci	R-13 + R-7.5ci	R-13 + R-7.5ci	R-13 + R-7.5ci	R-13 + R-7.5ci	R-13 + R-7.5ci	R-13 + R-7.5ci	R-13 + R-7.5ci	R-13 + R-15.6ci	R-13 + R-7.5ci	R-13 + R-17.5ci	
Wood framed and other	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-3.8ci or R-20	R-13 + R-7.5ci or R-20 + R-3.8ci	R-13 + R-7.5ci or R-20 + R-3.8ci	R-13 + R-7.5ci or R-20 + R-3.8ci	R-13 + R-7.5ci or R-20 + R-3.8ci	R-13 + R-7.5ci or R-20 + R-3.8ci	R-13 + R-15.6ci or R-20 + R-10ci	R-13 + R-15.6ci or R-20 + R-10ci
WALLS, BELOW GRADE																	
Below-grade wall ^d	NR	NR	NR	NR	NR	NR	R-7.5ci	R-7.5ci	R-7.5ci	R-7.5ci	R-7.5ci	R-7.5ci	R-10ci	R-10ci	R-10ci	R-12.5ci	
FLOORS																	
Mass	NR	NR	R-6.3ci	R-8.3ci	R-10ci	R-10ci	R-10ci	R-10.4ci	R-10ci	R-12.5ci	R-12.5ci	R-12.5ci	R-15ci	R-16.7ci	R-15ci	R-16.7ci	
Joist/framing	NR	NR	R-30	R-30	R-30	R-30	R-30	R-30	R-30	R-30	R-30	R-30e	R-30e	R-30e	R-30e	R-30e	
SLAB-ON-GRADE FLOORS																	
Unheated slabs	NR	NR	NR	NR	NR	NR	R-10 for 24" below	R-10 for 24" below	R-10 for 24" below	R-10 for 24" below	R-10 for 24" below	R-15 for 24" below	R-15 for 24" below	R-15 for 24" below	R-15 for 24" below	R-20 for 24" below	
Heated slabs ^d	R-7.5 for 12" below	R-7.5 for 12" below	R-7.5 for 12" below	R-7.5 for 12" below	R-10 for 24" below	R-10 for 24" below	R-15 for 24" below	R-15 for 24" below	R-15 for 36" below	R-15 for 36" below	R-15 for 36" below	R-20 for 48" below	R-20 for 48" below	R-20 for 48" below	R-20 for 48" below	R-20 for 48" below	
OPAQUE DOORS																	
Swinging	U-0.61	U-0.61	U-0.61	U-0.61	U-0.61	U-0.61	U-0.61	U-0.61	U-0.37	U-0.37	U-0.37	U-0.37	U-0.37	U-0.37	U-0.37	U-0.37	
Roll-up or sliding	R-4.75	R-4.75	R-4.75	R-4.75	R-4.75	R-4.75	R-4.75	R-4.75	R-4.75	R-4.75	R-4.75	R-4.75	R-4.75	R-4.75	R-4.75	R-4.75	

